

1438 Balboa Ave  
Panama City, FL 32401

Tel: (850) 769-4773  
Fax: (850) 872-9967  
www.soeearth.com

Jackson County District Schools  
2903 Jefferson Street  
Marianna, Florida 32446

August 17, 2009

Attention: Mr. Stuart Wiggins

Subject: Asbestos Abatement of Vinyl Asbestos Floor Tile and Mastic Adhesive, Book  
Storage Room, Golson Elementary School, Marianna, Florida

Dear Mr. Wiggins:

On August 5, 2009, a representative of our firm collected a sample of floor tile and mastic tile adhesive in the book storage room at Golson Elementary school in Marianna, Florida. The analytical test results from Carolina Environmental, Inc. are attached which indicate 12% Chrysotile asbestos in the floor tile and 5% Chrysotile asbestos in the mastic adhesive.

Subsequently, the floor tile and mastic was abated by Cross Construction. Final air clearance samples were obtained on August 10, 2009. Clearance samples were analyzed by both Phase Contract Microscopy (PCM) and Transmission Electron Microscopy (TEM). No asbestos was detected in the TEM test and the concentration was below detection limits and the standard clearance criteria of 70 structures per mm<sup>2</sup>. Both analyses indicated that the abatement had been completed in accordance with standard procedures and analytical results were below normal clearance criteria, therefore, the room could be reoccupied. The analytical results are attached.

We appreciate the opportunity to be of service to you on this project. Should you have any questions or require additional information, please contact our office.

Sincerely,

**SOUTHERN EARTH SCIENCES, INC.**



Michael K. Varner, P.E.  
Asbestos Consultant No. 0023  
State of Florida

8/17/09